



REVISION SCHEDULE				
REV. NO.	REV. DESCRIPTION	REV. DATE	DRAWN	CHECKED
PL1	ISSUED FOR PLANNING	10/09/2024	FC	KOM
PL2	ISSUED FOR PLANNING	12/02/2025	FC	KOM
PL3	ISSUED FOR PLANNING	08/04/2025	FC	KOM
PL4	ISSUED FOR PLANNING	10/04/2025	FC	KOM

DRAINAGE LEGEND	
	COMBINED SEWER (EXISTING)
	FOUL SEWER (NEW)
	WATER MAIN (EXISTING)
	WATER MAIN (PROPOSED)
	FOUL SEWER MANHOLE (NEW)
	COMBINED SEWER MANHOLE (EXISTING)
	POP UP
	FLOOR GULLY
	NEW FIRE HYDRANT
	NEW SLUICE VALVE
	NEW METER

- DRAINAGE NOTES:**
- READ IN CONJUNCTION WITH ALL RELEVANT ARCHITECT'S AND ENGINEER'S DRAWINGS.
  - ALL WATER SERVICES MANHOLES, PIPE MATERIALS AND OTHER FEATURES SHALL COMPLY WITH THE LOCAL AUTHORITY AND UISCE EIREANN'S CODES OF PRACTICE FOR THE RELEVANT ASSET
  - WHERE COVER TO PIPES IS LESS THAN 1.2M IN ROADS, 1.0M IN PUBLIC AREAS AND 0.8M IN GRASSED/LANDSCAPED AREAS, SURROUND THE PIPE UP TO 150MM WITH 100MM CONCRETE AND LARGER PIPES WITH 150MM CONC.
  - BACK-FILL TRENCHES IN ROADS WITH MOT STONE COMPACTED IN LAYERS.
  - CLOSE ROAD GULLIES IN THE DIRECTION OF TRAFFIC FLOW.
  - ADJUST FOUNDATION DEPTHS, AS NECESSARY, ADJACENT TO SEWERS TO AVOID UNDERMINING OF THE FOUNDATIONS.
  - DO NOT SET OUT FROM THIS DRAWING. SETTING OUT TO BE DONE FROM ARCHITECT'S DRAWINGS.
  - MANHOLE COVERS AND FRAMES SHALL COMPLY WITH THE LA STANDARD PATTERN WITH MIN OPENING OF 600MM & WITH CLOSED KEYWAYS. HEAVY DUTY TYPE A MANHOLES IN ALL TRAFFICKED AREAS AND MEDIUM DUTY TYPE B ELSEWHERE, TO BS EN124. TYPE C MAY BE USED IN ENCLOSED PRIVATE GARDENS.
  - DOUBLE GULLIES, WITH SEPARATE CONNECTIONS TO MAIN, TO BE PROVIDED AT LOW POINTS AND AT THE ENDS OF CUL DE SACS. MAXIMUM RUN OF PIPE 15M. MINIMUM PIPE DIAMETER 150MM. MAXIMUM GULLY SPACING FOR ROADS UP TO 7M WIDE TO BE 50M UNO.
  - MANHOLES ON HOUSE DRAINS TO BE IN PRIVATE PROPERTY. HOUSE DRAINS SHALL NOT PASS THROUGH PROPERTY THEY DO NOT SERVE.
  - RECORD DRAWINGS OF THE AS CONSTRUCTED WORK SHALL BE MADE AVAILABLE TO CORA AT THE END OF THE PROJECT.

- NOTES REGARDING EXISTING PUBLIC SEWERS:**
- CONTRACTOR TO DETERMINE POSITION OF EXISTING SERVICES PRIOR TO ANY EXCAVATION WORK.
  - LEVELS AND LAYOUT OF EXISTING DRAINAGE TO BE CONFIRMED PRIOR TO COMMENCEMENT OF CONSTRUCTION WORK. CONTRACTOR TO ALLOW FOR ANY INVESTIGATION WORK REQUIRED.
  - CONTRACTOR TO ALLOW FOR INVESTIGATION WORK TO LOCATE EXISTING SERVICES AND PROVIDE NEW CONNECTION FROM PROPOSED EXTENSION TO DISCHARGE TO EXISTING FOUL DRAINAGE SYSTEM.
  - EXISTING FOUL SEWER TO BE RETAINED - SUBJECT TO SUITABILITY. CONTRACTOR TO ALLOW FOR CCTV CAMERA SURVEY OF EXISTING NETWORK. ALL NEW CONNECTIONS TO BE FORMED STRICTLY IN ACCORDANCE WITH IRISH WATER DETAILS.

- FOUL NOTES:**
- POP UPS, GULLIES AND OTHER FEATURES TO BE COORDINATE WITH PROJECT STAKEHOLDERS. EXTERNAL LANDSCAPING AND FINAL LEVELS TO BE CONFIRMED.
  - INSPECTION CHAMBER IN THE FOOTPATH FOR EACH HOUSE TO BE ≈ 1m FROM THE FRONT DOOR AS PER STD-WW-13.

**NOTE:**  
REFER TO CORA SHEET C-007 FOR DETAILED BLOCK STRATEGY, CORA SHEET C-008 FOR LONG SECTIONS, AND CORA SHEET C-0009 FOR FOUL SEWER COVER & INVERT LEVELS TABLE.

Drawing Stage:  <
---